



केन्द्रीय विद्युत अनुसंधान संस्थान

(भारत सरकार की सोसाइटी, विद्युत मंत्रालय)

प्रो.सर.सी.वी. रामन रोड, सदाशिवनगर डाक घर, पो.बा.सं. 8066, बेगलूर - 560 080, भारत

CENTRAL POWER RESEARCH INSTITUTE

(A Government of India Society, Ministry of Power)

Prof. Sir C.V. Raman Road, Sadashivanagar Post Office, P.B. No. 8066, Bengaluru - 560 080, India.
website : <http://cpri.res.in/>

Phone: 080-22072353
email: skdas@cpri.in

SHORT CIRCUIT LABORATORY

No. CPRI/SCL/HRTL/PR/01

Dated: 23.02.2023

M/s. A.BOND STRANDS PRIVATE LIMITED,
No. 164, Developed Plots, Perungudi,
Chennai – 600 096, India.

PROVISIONAL REPORT

Kind Attn: **Mr. V. Parthasarathy**, Q. C. Manager

Sub: Continuous current test on 12kV, 1250 A HT Panel with VCB.

Ref: Customer request form dated: 17.02.2023

Dear Sir,

This is to certify that, HT Panel with VCB of rating 12kV, 1250A, bearing Serial No. P0001 and with CPRI sample code No. HVD23S0078 has been submitted for the following type test(s) as per subclause(s) 7.5 of IEC 62271-200:2021 & IEC 62271-1:2017.

i) Continuous current test at 1250A

The above type test(s) has been completed on 20.02.2023 and the test results are within limits.

The final report will be issued shortly.

Thanking you.

Yours faithfully,


(Swaraj Kumar Das)
Additional Director/HOD